

NOTES

- 1 Be sure to install wire connection port to be directed downward.
- 2 Be sure to secure sufficient space for brazing work.
- 3 Be sure to secure the space of 400mm or more when you cannot install the inspection hatch right under the unit.
- 4 Install the product in buildings that uses gypsum boards (9.5mm thick or more) for ceiling materials because the product generates the flowing sound of refrigerant. It is recommended to install the product away from places or rooms where the sound is annoying. Refer to the following sketch to select a suitable place of installation.

Location of microphone



Over all (dB)

Distance from BEV unit X (m)	Scale A
1.5	40
3.0	37
5.0	35