

3D059129F

## NOTES


1. Be sure to install wire connection port to be directed downward.
2. Be sure to secure the sufficient space for brazing work.
3. Be sure to secure the space of 400mm or more when you cannot install the inspection hatch right under the unit.
4. Install the product in buildings that use gypsum boards (9.5mm thick or more) for ceiling materials because the product generates the flowing sound of refrigerant. It is recommended to install the product away from places or rooms where the sound is annoying. Refer to the following sketch to select a suitable place of installation.

Over all (dB)

Distance from BEV unit X(m)	Scale A
1.5	40
3.0	37
5.0	35

(B,G,N is already rectified)

Location of microphone



No.	Parts name	Description
1	Liquid pipe connection port	ø 6.4 mm brazing connection
2	Hanger	
3	Suspension bolt	
4	Wire connection port	Indoor unit connection
5	Wire connection port	Outdoor unit connection
6	Wire connection port	Power supply • Ground