



Unit:mm

Model name	Outdoor unit 1	Drawing N°.	Outdoor Unit 2	Drawing N°.	Outdoor unit 1	Drawing N°.
RQCEQ460P	RQEQ180P	3D066441	RQEQ140P	3D066441	RQEQ140P	3D066441
RQCEQ500P	RQEQ180P	3D066441	RQEQ180P	3D066441	RQEQ140P	3D066441
RQCEQ540P	RQEQ180P	3D066441	RQEQ180P	3D066441	RQEQ180P	3D066441
RQCEQ636P	RQEQ212P	3D066441	RQEQ212P	3D066441	RQEQ212P	3D066441

**NOTES**

- Heights of walls  
 Front: 1500mm  
 Suction side: 500mm  
 Side: Height unrestricted  
 The installation space shown in this figure is based on the condition of cooling operation at the outdoor air temperature of 35°C.  
 The installation space of suction side shown above must be expanded in the following case.  
 - Design outdoor temperature becomes over 35°C.  
 - Operating over Max. operating load  
 (In case of causing a heavy heating load at indoor unit side)
- If the above wall heights are exceeded then h/2 and h/1 should be added to the front and suction side service spaces respectively as shown in the following figure.
- When installing the units the most appropriate pattern should be selected from those shown above in order to obtain the best fit in the space available always bearing in mind the need to leave enough room for a person to pass between units and wall for the air to circulate freely. (If more units are to be installed than are catered for in the above patterns your layout should take account of the possibility of short circuits.)
- The units should be installed to leave sufficient space at the front for the on site refrigerant piping work to be carried out comfortably.