

Notes

1. Location of nameplate

The unit nameplate is located on the control box cover.

The decoration panel nameplate is located on the piping-side panel frame, under the corner cover.

2. When installing optional accessories, refer to their respective documentation.

3. Make sure the distance between the ceiling and the cassette does not exceed 35 mm.

The maximum ceiling opening is 910 mm.

4. When the conditions in the ceiling exceed 30°C ambient temperature and 80% relative humidity, or when fresh air is inducted into the ceiling, additional insulation is required (polyethylene foam, thickness 50 mm).

5. When installing a sensor kit, there will be a sensor on this location. For details, see the drawing of the sensor kit.

6. When installing a wireless controller, there will be a receiver on this location. For details, see the drawing of the wireless controller.

